



## REQUIREMENTS FOR AUTHORIZATION OF TEMPORARY POWER

The following prerequisites for authorization of temporary power to the utility company by the City of Sandy Springs must be confirmed by your private engineer inspector (must be on City's List of Approved Private Engineer Inspectors) or from a separate inspection by a City Inspector, before we will notify the power company:

1. All electrical circuit(s) requested to be energized must be installed according to 2005 NEC with 2006 Georgia State Amendments.
2. Meter base, main disconnect and grounding system must be installed according to 2005 NEC with 2006 Georgia State Amendments.
3. All panel covers must be in place.
4. The building must be completely secured to prevent entry by unauthorized personnel during non-working hours.
5. A complete and correct copy of the Private Engineers inspection report must be transmitted to and be reviewed by this office prior to the authorization being issued.
6. An application for Temporary Power must be made with the City of Sandy Springs and the appropriate fee paid prior to issuance of authorization. A copy of this form is available on the City's website (Request for Temporary Power)

**Temporary Power Authorization will not be issued until ALL of these requirements are met.**